

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 05/31/2016
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155828		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 B. WING _____		(X3) DATE SURVEY COMPLETED R 05/17/2016	
NAME OF PROVIDER OR SUPPLIER HERITAGE OF FORT WAYNE, THE				STREET ADDRESS, CITY, STATE, ZIP CODE 5250 HERITAGE PARKWAY FORT WAYNE, IN 46835			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the Life Safety Code Recertification, State Licensure and Quality Assurance Walk-thru Survey conducted on 04/05/16 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 05/17/16</p> <p>Facility Number: 012931 Provider Number: 155828 AIM Number: 201278730</p> <p>At this PSR survey, The Heritage of Fort Wayne was found in compliance with Requirements for Participation Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety From Fire and the 2000 Edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC), Chapter 18, New Health Care Occupancies and 410 IAC 16.2-3.</p> <p>This one story facility was determined to be of Type V (111) construction and fully sprinklered. The facility has a fire alarm system with smoke detection in the corridors, in all areas open to the corridors with hard wired smoke detectors in all resident rooms. The facility has a capacity of 84 and had a census of 73 at the time of this visit.</p> <p>All areas where residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p> <p>Quality Review completed on 05/27/16 - DA</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.